

**SECTION 00 9116
ADDENDUM NO. 4**

PROJECT: BROOKWOOD ELEMENTARY SCHOOL
BID PACKAGE #1; ROOF AND HVAC
DALTON, GEORGIA

OWNER: DALTON PUBLIC SCHOOLS
412 SOUTH HAMILTON STREET
DALTON, GEORGIA
(706)-226-3521

ARCHITECT: JAMES W. BUCKLEY & ASSOCIATES, INC.
P.O. BOX 466, 423 PINE AVENUE SUITE 200
ALBANY, GEORGIA, 31702
PHONE (229)-883-4698, FAX (229)-883-0936

CM FIRM PARRISH CONSTRUCTION GROUP, INC
675 MANSELL ROAD, SUITE 230
ROSWELL, GEORGIA 30076
PHONE 678-382-0712; FAX 678-382-0722

DATE ISSUED: MARCH 2, 2018

BID DATE: MARCH 6, 2018

CONTRACT DOCUMENTS DATED **FEBRUARY 19, 2018**, ARE HEREBY MODIFIED AND INTERPRETED AS NOTED HEREIN. ACKNOWLEDGE RECEIPT OF ADDENDUM IN THE SPACE PROVIDED ON BID PROPOSAL. FAILURE TO DO SO MAY, AT THE OWNER'S OPTION, SUBJECT THE BIDDER TO DISQUALIFICATIONS.

CHANGES TO THE PROJECT MANUAL

1. SECTION 07 5419; POLYVINYL-CHLORIDE (PVC) ROOFING
 - A. Page 07 5419-5; Paragraph 2.03.B.1:
 1. Change minimum thickness of membrane from 60 mils TO 80 mils.

END OF ADDENDUM NO. 4