

**SECTION 00 9116
ADDENDUM NO. 4**

PROJECT: DALTON PUBLIC SCHOOLS
SECURITY IMPROVEMENTS
DALTON, GEORGIA

OWNER: DALTON PUBLIC SCHOOLS
412 SOUTH HAMILTON STREET
DALTON, GEORGIA
(706)-226-3521

ARCHITECT: JAMES W. BUCKLEY & ASSOCIATES, INC.
P.O. BOX 466, 423 PINE AVENUE SUITE 200
ALBANY, GEORGIA, 31702
PHONE (229)-883-4698, FAX (229)-883-0936

DATE ISSUED: MAY 15, 2018

BID DATE: MAY 18, 2018 (Revised)

CONTRACT DOCUMENTS DATED **APRIL 18, 2018**, ARE HEREBY MODIFIED AND INTERPRETED AS NOTED HEREIN. ACKNOWLEDGE RECEIPT OF ADDENDUM IN THE SPACE PROVIDED ON BID PROPOSAL. FAILURE TO DO SO MAY, AT THE OWNER'S OPTION, SUBJECT THE BIDDER TO DISQUALIFICATIONS.

CHANGES TO THE PROJECT MANUAL

1. **SECTION A; INVITATION TO BID**
 - A. **Page A-1; Paragraph A-01:**
 1. Change Bid Date from May 17, 2018 to May 18, 2018.
 2. Change Bid Time from 2:00 PM to 10:00 AM

CHANGES TO THE DRAWINGS

NOTE: "Clouds" are provided on drawings for the convenience of the Contractor only! "Clouds" are without force and effect on the contract documents

1. **SHEET A1.7; ANNEX BUILDING:**
 - A. **Floor Plan:**
 1. For the purpose of bidding, the contractor shall include the costs for the replacement of the door hardware at the Annex Building with the costs for the Northstar Building (Blue Ridge Campus).
2. **SHEET A3.0:**
 - A. **Annex Building Hardware Schedule:**
 1. For the purpose of bidding, the contractor shall include the costs for the replacement of the door hardware at the Annex Building with the costs for the Northstar Building (Blue Ridge Campus).
3. **SHEET A3.1; PARK CREEK:**
 - A. **Door Schedule:**
 1. All existing locksets are mortised type locksets, not the cylindrical type noted on Hardware Schedule. At each door noted as being a cylindrical lockset, revise schedule as follows:
 - a. Change door lockset from 'Cylindrical' to 'Mortised'
 - b. Change Hardware Set Number from 'HW-1' to 'HW-2'.
 2. Doors 123.1 and 124:
 - a. Doors do not exist in these locations.
 - b. Delete new door hardware. No work required at these doors.

4. SHEET A3.4; DALTON MIDDLE SCHOOL:

A. Door Schedule:

1. Door 207: Change Lockset type from 'Cylinder' to 'Passage'. Change hardware Set from HW-1 to HW-3.
2. Door 208: Change Lockset type from 'Cylinder' to 'Passage'. Change hardware Set from HW-1 to HW-3.
3. The following doors have cylindrical locksets as indicated on the door schedule. These locksets shall be removed and replaced with new cylindrical locksets:
 - a. 661, 662, 663, 663.1, 664, 664.1, 761, 761.1, 762, 762.2, 902, 903, 904, 905, 905.1, 911, 913, 914
4. All existing locksets, other than those listed above and other than 'passage' sets, are mortised type locksets, not the cylindrical type noted on Hardware Schedule. At each door noted as being a cylindrical lockset, revise schedule as follows:
 - a. Change door lockset from 'Cylindrical' to 'Mortised'
 - b. Change Hardware Set Number from 'HW-1' to 'HW-2'.
5. Door 531.2:
 - a. A door do not exist in this location.
 - b. Delete new door hardware. No work required at this door.

5. SHEET A3.5.1; DALTON HIGH SCHOOL ATHLETIC FACILITIES:

A. Door Schedule:

1. Refer to Sheet A1.5.4 for the Dalton High School Athletic Facilities floor plan and door numbers.

END OF ADDENDUM NO. 4